


# Updating AS/NZS4777.2 to manage grid disturbances

Rooftop PV Impacts on the Grid Operator

Taru Veijalainen

# About AEMO

*Shaping a better energy future for all Australians*



We operate Australia's National Electricity Market and power grid in Australia's eastern and south-eastern seaboard, and the Wholesale Electricity Market and power grid in south-west WA.



As the Independent System Operator we coordinate the supply and demand of electricity in real-time from generators to load.



The dispatch of generation is based on market participant (or generator) bids.



Both markets supply more than 220 terawatt hours of electricity each year.



Ownership


**40%**

Market participants

**60%**

Governments of Australia

# Changing Load Profile



In the last month, SA repeatedly set new minimum demands:

- 29/09/2019 12:30: 574 MW
- 12/10/2019 13:30: 533 MW
- 20/10/2019 13:30: 475 MW

20/10/2019 AEMO

# The growing level of consumer choice

## Rooftop PV generation capacity




9.6 GW to **22.4 GW**

## Embedded battery storage capacity




0.8 GW to **15.9 GW**



Source: AEMO 2019 ISP Insights, neutral scenario

# Key Challenges of increasing rooftop PV


- Over-voltage at the distribution network
- 'Reverse electricity flows' across Australia's distribution networks
- Managing supply and demand will be more difficult
- Ramping needs in the evening are exacerbated
- Response of distributed energy resources (DER) to disturbances is uncertain.



Fast DER scenario

Source: CSIRO 2019

# Addressing challenges through performance standards




AS/NZS4777.2 is the Australian Standard for Grid Connection of energy system via inverters:  
Inverter Requirements

- AEMO submitted a proposal to review the Standard in June 2019,
- CEC provided feedback that was incorporated into the submission,
- Currently the exact changes/values are being consulted on with inverter manufacturers, distribution network service providers, and installers (through the CEC).

# Loss of 40% of distributed PV



- 3 March 2017: Series of faults resulted in the loss of ~610 MW of generation in SA
- Flows on Heywood interconnector increased to ~918 MW.
- Estimated that demand reduced ~400 MW
- Estimated that distributed PV reduced by ~150 MW (40%)
- Projecting forwards, loss of 40% of DER will exceed credible contingency sizes, possibly requiring additional frequency control reserves.

3 March 2017: Demand in South Australia:



Generation by distributed PV:

Data from Solar Analytics (~200 distributed PV systems) confirms disconnection of some inverters:



Analysis by Naomi Stringer, UNSW Sydney  
Data from Solar Analytics

# Disturbance withstand capabilities

Proposed changes are intended to:

- Align their expected response to disturbances (as much as possible) to large-scale generators and International Standards,
- Ensure inverters have a minimum response during disturbances (provision of minimum requirements),
- Provide immunity to transmission events while maintaining adequate protection from islanding for distribution networks,
- Define clear zones of operation to provide clarity to manufacturers on the required behaviour and responses of inverters during system conditions.

**TABLE 13**  
**PASSIVE ANTI-ISLANDING SET-POINT VALUES**

Protective function	Protective function limit	Trip delay time	Maximum disconnection time
Undervoltage (V<)	180 V	1 s	2 s
Overtoltage 1 (V>)	260 V	1 s	2 s
Overtoltage 2 (V>>)	265 V	—	0.2 s
Under-frequency (F<)	47 Hz (Australia) 45 Hz (New Zealand)	1 s	2 s
Over-frequency (F>)	52 Hz	—	0.2 s

## Disturbance ride-through

- Extend as much as possible to suit both AEMO and DNSP needs

## Multiple voltage disturbances

- Ride-through requirements for multiple voltage disturbances

## Phase angle jump

- Specify withstand requirements for Phase Angle jumps.

## RoCoF ride-through

- Specify withstand requirements for RoCoF

## Momentary cessation

- Determine appropriate requirements, considering periods with most generation from DER

# Power Quality Modes

## Volt-Var and Volt-Watt

- Default enablement
- Determine relative priorities of control schemes
- Consider smaller deadbands and settings aligned with international standards

## Over-frequency response



- Specify required response times

## Under-frequency response

- Require response from already curtailed inverters, of storage inverters
- Specify response times

Proposed changes are intended to:

- Align expected response to International Standards (where applicable),
- Provide an autonomous response to local voltage management issues and maintain the grid within technical limits,
- Increase hosting capacity of distribution network feeders,
- Ensure inverters do not exacerbate disturbances and help to manage their response,



# Compliance, Measurement and Control

## Compliance

- Review compliance mechanisms.
- Include new compliance requirements for new parameters.


## Measurement and Control Functionality

- Define minimum requirements for measurement and control system operation.
- Define prioritisation of responses.

## Proposed changes are intended to:

- Provide minimum requirements for system measurement and control (provides certainty to inverter response),
- Optimise DER responses so they do not cause control system instability,
- Provide degree of certainty to AEMO on the expected response of the DER generation fleet (to incorporate into our models).

## Separation event 25 Aug 2018:



Analysis by Naomi Stringer, UNSW Sydney  
Data from Solar Analytics

# Summary

- We are seeing increasing penetrations of DER across Australia (mostly in the form of PV),
- This is creating challenges for networks and AEMO,
- Addressing *some* challenges through revising AS/NZS4777.2, includes:
  - **Disturbance withstand:** Optimise DER response so that during power system disturbances DER does not disconnect and exacerbate the event.
  - **Power Quality Support modes:** DER provides an autonomous response and increases hosting capacity.
  - **Measurement and Control:** Define minimum specifications for DER devices.
- Consultation and Review of the Standard is currently underway.



**AEMO**

AUSTRALIAN ENERGY MARKET OPERATOR